



Norwegian University of
Science and Technology

BIM based iterative simulation - efficient building design: a case study

Martin Tallberg and Rolf André Bohne

Department of Civil and Environmental Engineering,
NTNU, Høgskoleringen 7A,
7491 Trondheim, Norway

Martin Tallberg





Building facades (Revit 2018)



Room and space allocation (IDA-ICE 4.8)

Building design envelope







		TEK-17	nZEB
Roof Function	Materials	U-value: 0.13 W/m ² K Thickness (mm)	U-value: 0.07 W/m ² K Thickness (mm)
Finish (external)	roof tiles (11 tilt)	-	-
Membran layer	EPDM Membrane	20	20
Thermal/air layer	air in ltrating barrier	-	-
Structure	timber (90x315)	315	315
Insulation	mineral wool	260	500
Membran layer	vapor retarder	-	-
Finish (internal)	Gypsum	-	-
External walls Function	Materials	U-value: 0.18 W/m ² K Thickness (mm)	U-value: 0.095 W/m ² K Thickness (mm)
Finish (external)	horizontal wood panels	-	-
Membran layer	EPDM Membrane	20	20
Thermal/air layer	air in ltrating barrier	-	-
Structure	timber (90x315)	315	315
Insulation	Mineral wool	175	350
Membran layer	vapor retarder	-	-
Finish (internal)	Gypsum	-	-
Floor Function	Materials	U-value: 0.09 W/m ² K Thickness (mm)	U-value: 0.069 W/m ² K Thickness (mm)
Finish (oor)	wood ooring	-	-
Membran layer	vapor retarder	-	-
Insulation	mineral wool	350	500
Structure	concrete (24.1 mPa)	125	125
Thermal/air layer	damp pro ng	-	-
Membran layer	randon membrane	-	-
Substrate 1	Concrete (24.1 mPa)	300	300
Substrate 2	hardcore	100	100
Windows TEK-17	WWR 6.6% SHGC and ST	U-value	Internal/external emissivity
	0.15 and 0.1	0.6	0.837 (default)
Windows nZEB	WWR 6.6% SHGC and ST	U-value	Internal/external emissivity
	0.15 and 0.1	0.8	0.837 (default)
Insulation Mineral wool	Thermal conductivity 0.036 W/(mK)	Density) 20 kg/m ³	Speci c heat 750 J/(kg K)


Room and space data

Zones	People	Lightning*	Equipment*	Occupancy	Lightning	Equipment
Main area	2	100 W	3100 W	07-09 17-22	07-09 17-22	07-09 17-22
Bathroom	1	100 W	1750 W	Never present	Always o	07-09 17-22
Bedroom 1	1	40 W	50 W	21-07	Always o	21-07
Bedroom 2	1	40 W	50 W	21-07	Always o	21-07
Zones	Height	Heating	Cooling	Ventilation	ACH	Supply air
All zones	2.6m	21	25	AHU CAV	0.5	2 L/sm ² height

*Effect (Watt) for equipment and lightning was obtained from [?]


Envelope transmission: Norwegian TEK-17 standard

Month	Walls	Roof	Floor	Windows	Doors	Thermal bridges
						
1	-318.5	-174.9	-19.0	-232.7	-78.3	-126.7
2	-255.6	-147.2	-16.3	-194.1	-62.6	-105.2
3	-228.9	-146.6	-16.9	-190.9	-55.6	-102.8
4	-138.6	-116.6	-15.3	-148.8	-37.5	-79.5
5	-59.3	-80.0	-13.2	-95.2	-12.5	-48.1
6	-27.4	-63.3	-13.2	-74.0	-4.3	-36.8
7	-14.3	-55.9	-14.5	-63.1	-1.4	-30.3
8	-32.2	-57.0	-9.7	-67.5	-7.0	-33.1
9	-95.9	-78.0	-7.9	-96.1	-22.9	-49.4
10	-170.1	-106.8	-10.5	-137.2	-41.7	-72.6
11	-223.2	-126.0	-11.4	-164.8	-34.7	-88.7
12	-276.6	-151.2	-13.8	-200.6	-68.0	-108.6
Total	-1860.5	-1303.6	-161.7	-1665.0	-446.5	-881.9
During heating	-1723.3	-1145.2	-76.3	-1527.3	-421.9	-809.5
During cooling	-9.7	-23.5	-33.4	-17.0	1.2	-7.7
Rest of time	-127.5	-134.9	-52.0	-120.6	-25.8	-64.7










Energy use: Norwegian TEK-17 standard

		Purchased energy		Peak demand
		kWh	kWh/m ²	kW
■	Lighting, facility	308	5.3	0.17
■	Equipment, facility	1061	18.3	1.9
■	HVAC aux	272	4.7	0.19
■	Electric heating	3226	55.7	2.68
Total, Facility electric		4867	84.1	
Total		4867	84.1	




Envelope transmission: ZEB recommendations

Month	Walls	Roof	Floor	Windows	Doors	Thermal bridges
						
1	-204.2	-171.9	-8.9	-179.6	-80.2	-62.5
2	-164.2	-144.6	-9.3	-149.9	-63.9	-52.0
3	-147.0	-143.8	-11.4	-147.6	-56.4	-50.9
4	-102.8	-114.1	-11.9	-115.1	-37.5	-39.6
5	-46.5	-79.3	-14.0	-73.9	-12.2	-24.1
6	-21.0	-63.5	-14.4	-58.0	-4.2	-18.6
7	-12.8	-56.7	-15.7	-50.3	-1.7	-15.6
8	-22.7	-57.5	-10.5	-53.5	-7.1	-17.0
9	-62.6	-76.9	-7.7	-74.4	-22.6	-24.7
10	-108.6	-104.6	-6.9	-106.1	-41.8	-36.1
11	-143.0	-123.5	-6.9	-127.4	-55.2	-44.0
12	-177.5	-148.6	-7.8	-155.0	-69.2	-53.7
Total	-1206.9	-1285.0	-125.3	-1290.9	-451.9	-438.7
During heating	-1150.3	-1166.9	-43.8	-1197.5	-446.1	-409.4
During cooling	-8.4	-23.2	-26.9	-16.8	0.8	-4.7
Rest of time	-48.2	-94.9	-34.6	-76.6	-6.6	-24.6





Energy use: ZEB recommendations

		Purchased energy		Peak demand
		kWh	kWh/m ²	kW
■	Lighting, facility	308	5.3	0.17
■	Equipment, facility	1062	18.3	1.9
■	HVAC aux	272	4.7	0.19
■	Electric heating	2150	37.1	2.28
Total, Facility electric		3792	65.5	
Total		3792	65.5	



Design temperatures in main area (electric heating)



Break ven (PVGIS)

PVGIS												
Efficiency	16%				18%				20%			
Escalation	1.30%	2.80%	4.30%	5.00%	1.30%	2.80%	4.30%	5.00%	1.30%	2.80%	4.30%	5.00%
Break even	26	22.8	20.2	19	24.6	21.2	19	18.2	22.9	20	17.9	17

Comclusion

- The design option with the lowest energy demand was found to be the optional concept building with electric floor heating and a air-to-air heat pump designed according to the ZEB specifications.
 - By retrofitting the design from TEK-17 standard to nZEB, the energy demand reduction was found to be 22%.
- The cost of retrofitting was found to be neglect able, compared to the cost of energy efficient measures, like the photo voltaic system.
- Furthermore, experimental verification of the demonstrated energy demand potential is recommended.



Thank you.....

rolf.bohne@ntnu.no

